

P10 SLED9090D BRANCO FITA 7,2WM 2700K 80 - 1m



Luminária linear pendente com iluminação difusa.
Corpo em alumínio extrudado com acabamento na cor prata. Difusor em acrílico extrudado leitoso. Indicado para residência, recepção, escritório etc.

Fluxo luminoso – 356 lm/m

Potência – 7,7 W/m

Intensidade pico – 121cd

CCT – 2653K



IRC – 82,3

Coordenada CIE 1931 – x- 0,464 y- 0,412

A x L - 15x15

Peso - 0,35kg/m


IP - 20 - Uso Interno

IK - 00 – Não aplicável

Alimentação - 12vdc

Data do ensaio

18/01/2021 08:30:32



Facho de abertura

112,8°


Rf 85,8



Fidelity index Rf

Rg 95,2


Gamut index Rg

Hue Bin	R _f	Shifts (%)	
		Chroma	Hue
1	79	-12%	0%
2	81	-8%	7%
3	79	-3%	11%
4	90	1%	6%
5	95	3%	4%
6	94	3%	-1%
7	89	-3%	-7%
8	93	-3%	-1%
9	90	-6%	2%
10	87	-4%	7%
11	86	-1%	9%
12	86	6%	0%
13	86	4%	-10%
14	80	3%	-16%
15	83	-4%	-10%
16	78	-11%	-13%






TM-30: 85,8



CRI: 82,3 (R1-R8)



CRIRA R1-R8 / CRIR R1-R15

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
81,0	92,1	94,7	80,3	81,4	92,3	80,6	55,9	5,2	82,8	80,5	79,4	83,7	97,8	71,9

TM30 valores C. 16 valores extraídos dos 99.

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
79,1	80,6	78,9	90,2	94,5	93,9	88,8	93,3	89,7	87,2	86,4	86,4	85,9	80,0	83,0	77,7

Parametros de cor

Temperatura de cor	Índice de reprodução de cor	Reprodução de cor vermelho R9	Color fidelity	Color gamut	Color quality scale	Coordenada de cor cie 1931	Coordenada de cor cie 1931	Coordenada de cor	Coordenada de cor	Color deviation from black body
CCT	IRC	CRI R9	TM30 Rf	TM30 Rg	CQS	x	y	u	v	Δuv
2653 K	82,3	5,2	85,8	95,2	82,0	0,464	0,412	0,265	0,352	0,0002







Rf 85,8

Fidelity index Rf

Rg 95,2

Gamut index Rg

Hue Bin	R _f	Shifts (%)	
		Chroma	Hue
1	79	-12%	0%
2	81	-8%	7%
3	79	-3%	11%
4	90	1%	6%
5	95	3%	4%
6	94	3%	-1%
7	89	-3%	-7%
8	93	-3%	-1%
9	90	-6%	2%
10	87	-4%	7%
11	86	-1%	9%
12	86	6%	0%
13	86	4%	-10%
14	80	3%	-16%
15	83	-4%	-10%
16	78	-11%	-13%



Glare Evaluation According to UGR


p Ceiling		70	70	50	50	30	70	70	50	50	30
p Walls		50	30	50	30	30	50	30	50	30	30
p Floor		20	20	20	20	20	20	20	20	20	20
Room size X Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	20,9	22,1	21,2	22,4	22,7	20,8	22,0	21,0	22,3	22,6
	3H	22,4	23,6	22,8	24,0	24,2	22,2	23,5	22,7	23,8	24,1
	4H	23,0	24,2	23,5	24,6	24,9	22,9	24,1	23,4	24,4	24,7
	6H	23,6	24,6	23,9	24,9	25,4	23,5	24,5	23,8	24,9	25,3
	8H	23,7	24,7	24,1	25,1	25,5	23,7	24,7	24,0	25,0	25,5
	12H	23,8	24,8	24,2	25,1	25,6	23,8	24,8	24,2	25,2	25,7
4H	2H	21,5	22,7	21,9	23,0	23,3	21,4	22,6	21,8	22,9	23,2
	3H	23,3	24,3	23,7	24,7	25,2	23,2	24,2	23,6	24,5	25,0
	4H	24,0	24,9	24,5	25,3	25,9	23,9	24,8	24,4	25,3	25,8
	6H	24,6	25,4	25,1	25,8	26,2	24,5	25,4	25,1	25,8	26,2
	8H	24,7	25,5	25,3	25,9	26,4	24,8	25,6	25,3	26,0	26,4
	12H	24,9	25,5	25,4	26,0	26,5	25,0	25,6	25,5	26,1	26,6
8H	4H	24,3	25,1	24,8	25,5	25,9	24,2	25,0	24,7	25,4	25,8
	6H	25,0	25,6	25,5	26,1	26,7	25,0	25,6	25,5	26,1	26,7
	8H	25,3	25,8	25,8	26,4	27,0	25,4	25,9	25,9	26,4	27,1
	12H	25,5	25,9	26,1	26,5	27,1	25,6	26,1	26,3	26,6	27,3
12H	4H	24,3	24,9	24,8	25,4	25,9	24,2	24,9	24,7	25,3	25,8
	6H	25,1	25,6	25,6	26,2	26,8	25,1	25,6	25,6	26,2	26,8
	8H	25,4	25,8	26,0	26,4	27,0	25,5	25,9	26,1	26,4	27,1
Variation of the observer position for the luminaire distance S											
S = 1.0H		0,1 / -0,1					0,1 / -0,1				
S = 1.5H		0,1 / -0,2					0,1 / -0,2				
S = 2.0H		0,4 / -0,5					0,4 / -0,5				
Standard table		n/a					n/a				
Correction summand		n/a					n/a				
Corrected glare indices referring to 356 lm total luminous flux											


Coeficiente de utilização

Ceiling reflectance	80				70				50			30			10			0
Wall reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Floor reflectance	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	0
RCR	(RCR: Room Cavity Ratio) Room Values are expressed as percentage of Lumens delivered to the task surface																	
0	118	118	118	118	115	115	115	115	110	110	110	105	105	105	100	100	100	97
1	108	103	99	95	105	101	97	93	96	93	90	91	89	86	87	85	83	81
2	98	90	83	77	95	88	81	76	84	78	74	80	75	72	77	73	70	67
3	89	79	70	64	87	77	69	63	73	67	62	70	65	60	67	63	59	57
4	82	70	61	54	79	68	60	53	65	58	52	63	56	51	60	55	50	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	44	54	48	44	42
6	69	56	47	40	67	55	46	40	53	45	39	51	44	39	49	43	38	36
7	64	51	42	36	62	50	41	35	48	40	35	46	39	34	45	39	34	32
8	60	46	38	32	58	45	37	31	44	36	31	42	36	31	41	35	30	29
9	56	42	34	28	54	42	34	28	40	33	28	39	32	28	38	32	27	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23

Quantidade de luminárias

Luminaire budgetary diagram





Beam intensities from 1-20m

1m	2m	3m	4m	5m	6m	7m	8m	9m	10m	11m	12m	13m	14m	15m	16m	17m	18m	19m	20m
3,3ft	6,6ft	9,8ft	13,1ft	16,4ft	19,7ft	23ft	26,2ft	29,5ft	32,8ft	36,1ft	39,4ft	42,7ft	45,9ft	49,2ft	52,5ft	55,8ft	59,1ft	62,3ft	65,6ft
121lx	30lx	13lx	8lx	5lx	3lx	2lx	2lx	1lx	1lx	1lx	1lx	1lx	1lx	1lx	0lx	0lx	0lx	0lx	0lx
11,2fcd	2,8fcd	1,2fcd	0,7fcd	0,4fcd	0,3fcd	0,2fcd	0,2fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0fcd	0fcd	0fcd	0fcd	0fcd

Intensities in 0° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
121	120	118	116	112	109	103	96	90	82	73	64	55	45	35	24	14	6	2	1
100%	100%	98%	96%	93%	90%	85%	80%	74%	68%	61%	53%	46%	37%	29%	20%	12%	5%	1%	1%

Intensities in 90° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
121	120	117	115	111	106	100	94	87	79	71	62	52	43	33	23	15	8	3	1
100%	99%	97%	95%	92%	88%	83%	78%	72%	66%	59%	51%	43%	36%	27%	19%	13%	6%	2%	1%

Intensities in 180° c-plane


0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
121	120	118	116	112	109	103	96	90	82	73	64	55	45	35	24	14	6	2	1
100%	100%	98%	96%	93%	90%	85%	80%	74%	68%	61%	53%	46%	37%	29%	20%	12%	5%	1%	1%

Intensities in 270° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
121	120	117	115	111	106	100	94	87	79	71	62	52	43	33	23	15	8	3	1
100%	99%	97%	95%	92%	88%	83%	78%	72%	66%	59%	51%	43%	36%	27%	19%	13%	6%	2%	1%

Beam angle 50%	Field angle 10%	Cutoff angle 2,5%	Intensity ratio in 120° cone	Intensity ratio in 90° cone
112,8°	162,9°	176,9°	76,1%	51,6%

iso-candela diagram




10%	12 cd
20%	24 cd
30%	36 cd
40%	48 cd
50%	60 cd
60%	72 cd
70%	85 cd
80%	97 cd
90%	109 cd

Conditions:

Number of c-planes: 16

Candela at center: 121 cd

iso-lux diagram



3%	36,2m lx
5%	60,4m lx
10%	0,121 lx
30%	0,362 lx
50%	0,604 lx

Conditions:

Number of c-planes: 16

Lux at center: 1,21 lx

Lux distribution on a surface when lamp is mounted at 10 meters from the surface.

Potência



Vttagem: 12,0 V

Corrente: 0,640 A

Frequência: 0 Hz

FP: 1,0

THD



THD corrente: n/a

THD tensão: n/a