

K39N SLED9020N BRANCA FITA 15WM 4000K 95 - 1m

Luminária linear pendente com iluminação direta e indireta difusa. Corpo em alumínio extrudado com acabamento na cor branca. Difusor em acrílico extrudado leitoso. Indicado para residência, recepção, escritório etc. Acessórios são de acordo com a instalação.

Fluxo luminoso – 1260 lm/m

Potência – 29,8 W/m

Intensidade pico – 4054cd

CCT – 4036K



IRC – 96,3

Coordenada CIE 1931 – x- 0,379 y- 0,374

A x L - 115x38

Peso - 2,20kg/m


IP - 20 - Uso Interno

IK - 00 – Não aplicável

Alimentação - 12vdc

Data do ensaio

21/03/2023 13:05:17



Facho de abertura

360°


Rf 93,0



Fidelity index Rf

Rg 99,3


Gamut index Rg

Hue Bin	R _f	Shifts (%)	
		Chroma	Hue
1	94	-3%	0%
2	96	-1%	1%
3	95	-1%	2%
4	95	-2%	0%
5	94	-3%	0%
6	97	-1%	0%
7	95	-3%	1%
8	94	-2%	3%
9	92	-1%	6%
10	90	-1%	6%
11	88	4%	7%
12	92	4%	2%
13	93	3%	-3%
14	95	2%	-2%
15	90	1%	-6%
16	90	0%	-6%






TM-30: 93,0



CRI: 96,3 (R1-R8)



CRIRA R1-R8 / CRIR R1-R15

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
96,9	98,4	97,5	96,2	96,0	95,5	96,6	93,4	84,2	94,9	96,5	78,3	97,7	98,3	95,7

TM30 valores C. 16 valores extraídos dos 99.

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
93,8	96,1	94,8	94,6	93,8	97,4	95,3	94,4	91,6	89,9	88,2	91,9	92,9	94,8	89,9	89,8

Parametros de cor

Temperatura de cor	Índice de reprodução de cor	Reprodução de cor vermelho R9	Color fidelity	Color gamut	Color quality scale	Coordenada de cor cie 1931	Coordenada de cor cie 1931	Coordenada de cor	Coordenada de cor	Color deviation from black body
CCT	IRC	CRI R9	TM30 Rf	TM30 Rg	CQS	x	y	u	v	Δuv
4036 K	96,3	84,2	93,0	99,3	94,7	0,379	0,374	0,225	0,333	-0,0007







Rf 93,0

Fidelity index Rf

Rg 99,3

Gamut index Rg

Hue Bin	R _f	Shifts (%)	
		Chroma	Hue
1	94	-3%	0%
2	96	-1%	1%
3	95	-1%	2%
4	95	-2%	0%
5	94	-3%	0%
6	97	-1%	0%
7	95	-3%	1%
8	94	-2%	3%
9	92	-1%	6%
10	90	-1%	6%
11	88	4%	7%
12	92	4%	2%
13	93	3%	-3%
14	95	2%	-2%
15	90	1%	-6%
16	90	0%	-6%



Avaliação todas as amostras de cores

p Ceiling	70	70	50	50	30	70	70	50	50	30
p Walls	50	30	50	30	30	50	30	50	30	30
p Floor	20	20	20	20	20	20	20	20	20	20
Room size X Y	Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Variation of the observer position for the luminaire distance S										
n/a	n/a					n/a				
n/a	n/a					n/a				
n/a	n/a					n/a				
Standard table	n/a					n/a				
Correction summand	n/a					n/a				
Corrected glare indices referring to 1260 lm total luminous flux										


www.misterled.com.br


Coeficiente de utilização

Ceiling reflectance	80				70				50			30			10			0
Wall reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Floor reflectance	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	0
RCR	(RCR: Room Cavity Ratio) Room Values are expressed as percentage of Lumens delivered to the task surface																	
0	96	96	96	96	83	83	83	83	58	58	58	35	35	35	14	14	14	5
1	88	83	80	77	75	72	69	66	50	49	47	31	30	29	12	12	12	4
2	80	73	67	62	68	63	58	54	44	41	39	27	25	24	11	10	10	3
3	73	64	57	52	62	55	50	45	39	35	32	24	22	20	10	9	8	3
4	66	56	49	43	57	49	43	38	34	30	27	21	19	17	9	8	7	2
5	60	50	42	37	52	43	37	32	30	26	23	19	16	15	8	7	6	2
6	55	44	37	32	48	38	32	28	27	23	20	17	14	13	7	6	5	2
7	51	40	32	27	44	34	28	24	24	20	17	15	13	11	6	5	5	1
8	47	36	29	24	40	31	25	21	22	18	15	14	11	10	6	5	4	1
9	44	32	25	21	37	28	22	18	20	16	13	12	10	8	5	4	4	1
10	41	29	23	18	35	26	20	16	18	14	12	11	9	8	5	4	3	1

Quantidade de luminárias

Luminaire budgetary diagram





Beam intensities from 1-20m

1m	2m	3m	4m	5m	6m	7m	8m	9m	10m	11m	12m	13m	14m	15m	16m	17m	18m	19m	20m
3,3ft	6,6ft	9,8ft	13,1ft	16,4ft	19,7ft	23ft	26,2ft	29,5ft	32,8ft	36,1ft	39,4ft	42,7ft	45,9ft	49,2ft	52,5ft	55,8ft	59,1ft	62,3ft	65,6ft
21lx	5lx	2lx	1lx	1lx	1lx	0lx	0lx	0lx	0lx	0lx	0lx	0lx	0lx	0lx	0lx	0lx	0lx	0lx	0lx
1,9fcd	0,5fcd	0,2fcd	0,1fcd	0,1fcd	0,1fcd	0fcd	0fcd	0fcd	0fcd	0fcd	0fcd	0fcd	0fcd	0fcd	0fcd	0fcd	0fcd	0fcd	0fcd

Intensities in 0° c-plane

0°	9°	18°	27°	36°	45°	54°	63°	72°	81°	90°	99°	108°	117°	126°	135°	144°	153°	162°	171°
21	20	19	17	14	12	9	6	3	1	0	1	3	7	10	13	16	19	22	23
100%	98%	91%	81%	69%	56%	42%	28%	15%	5%	1%	5%	17%	32%	48%	64%	79%	93%	104%	112%

Intensities in 90° c-plane

0°	9°	18°	27°	36°	45°	54°	63°	72°	81°	90°	99°	108°	117°	126°	135°	144°	153°	162°	171°
21	20	19	16	14	11	8	5	3	1	0	1	4	7	11	14	18	21	24	26
100%	97%	89%	78%	65%	52%	38%	25%	13%	3%	1%	6%	18%	34%	50%	68%	86%	102%	116%	125%

Intensities in 180° c-plane


0°	9°	18°	27°	36°	45°	54°	63°	72°	81°	90°	99°	108°	117°	126°	135°	144°	153°	162°	171°
21	21	19	17	15	12	9	6	3	1	0	1	3	7	10	13	16	19	22	23
100%	98%	92%	83%	72%	58%	45%	31%	17%	5%	1%	5%	17%	32%	48%	64%	79%	93%	104%	112%

Intensities in 270° c-plane

0°	9°	18°	27°	36°	45°	54°	63°	72°	81°	90°	99°	108°	117°	126°	135°	144°	153°	162°	171°
21	21	19	17	15	12	9	6	3	1	0	1	4	7	11	14	18	21	24	26
100%	99%	92%	82%	69%	56%	42%	29%	17%	6%	1%	6%	18%	34%	50%	68%	86%	102%	116%	125%

Beam angle 50%	Field angle 10%	Cutoff angle 2,5%	Intensity ratio in 120° cone	Intensity ratio in 90° cone
360°	360°	360°	3,4%	2,4%

iso-candela diagram




10%	2 cd
20%	4 cd
30%	6 cd
40%	8 cd
50%	10 cd
60%	13 cd
70%	15 cd
80%	17 cd
90%	19 cd

Conditions:

Number of c-planes: 16

Candela at center: 21 cd

iso-lux diagram



3%	6,28m lx
5%	10,5m lx
10%	20,9m lx
30%	62,8m lx
50%	0,105 lx

Conditions:

Number of c-planes: 16

Lux at center: 0,209 lx

Lux distribution on a surface when lamp is mounted at 10 meters from the surface.

Potência

Vttagem: 12,0 V

Corrente: 2,48 A

Frequência: 0 Hz

FP: 1,0

THD



THD corrente: n/a

THD tensão: n/a