

SLED9122SF LUMINARIA LINEAR DE SOBREPOR 2x2 9,6Wm 3000K 80 1M



Fluxo luminoso – 548 lm/m

Potência – 9,4 W/m

Intensidade pico – 190cd

CCT – 2943K




IRC – 81,8

Coordenada CIE 1931 – x- 0,439 y- 0,401

Data do ensaio

23/08/2024 13:33:26



Facho de abertura

111,6°


Rf 83,5



Fidelity index Rf

Rg 93,9


Gamut index Rg

Hue Bin	R _f	Shifts (%)	
		Chroma	Hue
1	78	-12%	1%
2	80	-8%	7%
3	79	-3%	11%
4	90	-2%	4%
5	93	0%	3%
6	93	0%	-3%
7	86	-7%	-4%
8	90	-6%	1%
9	85	-6%	7%
10	79	-3%	13%
11	80	2%	15%
12	85	7%	2%
13	86	4%	-9%
14	79	4%	-17%
15	83	-5%	-9%
16	74	-10%	-18%






TM-30: 83,5



CRI: 81,8 (R1-R8)



CRIRA R1-R8 / CRIR R1-R15

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
80,8	92,7	93,9	78,1	80,9	91,0	80,2	56,4	4,8	82,9	76,7	71,1	84,0	97,5	72,9

TM30 valores C. 16 valores extraídos dos 99.

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
77,9	80,2	78,7	89,5	92,7	93,1	85,9	90,2	84,7	78,6	80,3	85,1	86,5	78,6	83,4	73,7

Parametros de cor

Temperatura de cor	Índice de reprodução de cor	Reprodução de cor vermelho R9	Color fidelity	Color gamut	Color quality scale	Coordenada de cor cie 1931	Coordenada de cor cie 1931	Coordenada de cor	Coordenada de cor	Color deviation from black body
CCT	IRC	CRI R9	TM30 Rf	TM30 Rg	CQS	x	y	u	v	Δuv
2943 K	81,8	4,8	83,5	93,9	80,8	0,439	0,401	0,253	0,347	-0,0016







Rf 83,5

Fidelity index Rf

Rg 93,9

Gamut index Rg

Hue Bin	R _f	Shifts (%)	
		Chroma	Hue
1	78	-12%	1%
2	80	-8%	7%
3	79	-3%	11%
4	90	-2%	4%
5	93	0%	3%
6	93	0%	-3%
7	86	-7%	-4%
8	90	-6%	1%
9	85	-6%	7%
10	79	-3%	13%
11	80	2%	15%
12	85	7%	2%
13	86	4%	-9%
14	79	4%	-17%
15	83	-5%	-9%
16	74	-10%	-18%



Avaliação todas as amostras de cores

Glare Evaluation According to UGR


p Ceiling		70	70	50	50	30	70	70	50	50	30
p Walls		50	30	50	30	30	50	30	50	30	30
p Floor		20	20	20	20	20	20	20	20	20	20
Room size X Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	20,0	21,2	20,2	21,5	21,8	20,0	21,2	20,2	21,5	21,8
	3H	21,4	22,7	21,9	23,0	23,2	21,4	22,7	21,9	23,0	23,2
	4H	22,1	23,3	22,5	23,6	23,9	22,1	23,3	22,5	23,6	23,9
	6H	22,6	23,7	23,0	24,0	24,4	22,6	23,7	23,0	24,0	24,4
	8H	22,8	23,8	23,1	24,1	24,6	22,8	23,8	23,1	24,1	24,6
	12H	22,9	23,9	23,3	24,2	24,7	22,9	23,9	23,3	24,2	24,7
4H	2H	20,6	21,8	21,0	22,1	22,3	20,6	21,8	21,0	22,1	22,3
	3H	22,4	23,4	22,8	23,7	24,2	22,4	23,4	22,8	23,7	24,2
	4H	23,1	24,0	23,5	24,4	25,0	23,1	24,0	23,5	24,4	25,0
	6H	23,6	24,5	24,2	24,9	25,3	23,6	24,5	24,2	24,9	25,3
	8H	23,9	24,7	24,4	25,1	25,5	23,9	24,7	24,4	25,1	25,5
	12H	24,0	24,7	24,5	25,1	25,6	24,0	24,7	24,5	25,1	25,6
8H	4H	23,4	24,1	23,9	24,5	25,0	23,4	24,1	23,9	24,5	25,0
	6H	24,1	24,7	24,6	25,2	25,8	24,1	24,7	24,6	25,2	25,8
	8H	24,4	25,0	25,0	25,5	26,2	24,4	25,0	25,0	25,5	26,2
	12H	24,7	25,1	25,3	25,6	26,3	24,7	25,1	25,3	25,6	26,3
12H	4H	23,4	24,0	23,9	24,5	25,0	23,4	24,0	23,9	24,5	25,0
	6H	24,2	24,7	24,7	25,3	25,9	24,2	24,7	24,7	25,3	25,9
	8H	24,5	25,0	25,1	25,5	26,1	24,5	25,0	25,1	25,5	26,1
Variation of the observer position for the luminaire distance S											
S = 1.0H		0,1 / -0,1					0,1 / -0,1				
S = 1.5H		0,1 / -0,2					0,1 / -0,2				
S = 2.0H		0,4 / -0,5					0,4 / -0,5				
Standard table		n/a					n/a				
Correction summand		n/a					n/a				
Corrected glare indices referring to 548 lm total luminous flux											


Coeficiente de utilização

Ceiling reflectance	80				70				50			30			10			0
Wall reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Floor reflectance	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	0
RCR	(RCR: Room Cavity Ratio) Room Values are expressed as percentage of Lumens delivered to the task surface																	
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101	98
1	108	103	99	95	105	101	97	94	96	93	90	92	90	87	88	86	84	82
2	98	90	83	77	96	88	82	76	84	79	74	81	76	72	77	74	71	68
3	90	79	71	64	87	77	70	64	74	68	62	71	66	61	68	64	60	57
4	82	70	61	54	80	68	60	54	66	59	53	63	57	52	61	56	51	49
5	75	62	53	47	73	61	53	46	59	51	46	57	50	45	55	49	44	42
6	70	56	47	41	68	55	47	41	53	46	40	51	45	40	50	44	39	37
7	65	51	42	36	63	50	42	36	48	41	35	47	40	35	45	39	35	33
8	60	46	38	32	58	46	38	32	44	37	32	43	36	31	42	36	31	29
9	56	43	34	29	55	42	34	29	41	34	28	40	33	28	38	32	28	26
10	53	39	31	26	51	39	31	26	38	31	26	37	30	26	36	30	25	24

Quantidade de luminárias

Luminaire budgetary diagram





Beam intensities from 1-20m

1m	2m	3m	4m	5m	6m	7m	8m	9m	10m	11m	12m	13m	14m	15m	16m	17m	18m	19m	20m
3,3ft	6,6ft	9,8ft	13,1ft	16,4ft	19,7ft	23ft	26,2ft	29,5ft	32,8ft	36,1ft	39,4ft	42,7ft	45,9ft	49,2ft	52,5ft	55,8ft	59,1ft	62,3ft	65,6ft
190lx	47lx	21lx	12lx	8lx	5lx	4lx	3lx	2lx	2lx	2lx	1lx	1lx	1lx	1lx	1lx	1lx	1lx	1lx	0lx
17,6fcd	4,4fcd	2fcd	1,1fcd	0,7fcd	0,5fcd	0,4fcd	0,3fcd	0,2fcd	0,2fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0fcd	0fcd

Intensities in 0° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
190	189	186	182	176	168	159	149	138	124	111	97	82	67	52	36	22	10	3	2
100%	100%	98%	96%	92%	88%	84%	79%	73%	66%	59%	51%	43%	35%	27%	19%	12%	5%	2%	1%

Intensities in 90° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
190	189	186	182	176	168	159	149	138	124	111	97	82	67	52	36	22	10	3	2
100%	100%	98%	96%	92%	88%	84%	79%	73%	66%	59%	51%	43%	35%	27%	19%	12%	5%	2%	1%

Intensities in 180° c-plane


0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
190	189	186	182	176	168	159	149	138	124	111	97	82	67	52	36	22	10	3	2
100%	100%	98%	96%	92%	88%	84%	79%	73%	66%	59%	51%	43%	35%	27%	19%	12%	5%	2%	1%

Intensities in 270° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
190	189	186	182	176	168	159	149	138	124	111	97	82	67	52	36	22	10	3	2
100%	100%	98%	96%	92%	88%	84%	79%	73%	66%	59%	51%	43%	35%	27%	19%	12%	5%	2%	1%

Beam angle 50%	Field angle 10%	Cutoff angle 2,5%	Intensity ratio in 120° cone	Intensity ratio in 90° cone
111,6°	162,3°	175,5°	77,3%	52,7%

iso-candela diagram




10%	19 cd
20%	38 cd
30%	57 cd
40%	76 cd
50%	95 cd
60%	114 cd
70%	133 cd
80%	152 cd
90%	171 cd

Conditions:

Number of c-planes: 16

Candela at center: 190 cd

iso-lux diagram



3%	57,0m lx
5%	95,0m lx
10%	0,190 lx
30%	0,570 lx
50%	0,950 lx

Conditions:

Number of c-planes: 16

Lux at center: 1,90 lx

Lux distribution on a surface when lamp is mounted at 10 meters from the surface.

Potência



Vttagem: 12,0 V

Corrente: 0,783 A

Frequência: 0 Hz

FP: 1,0

THD



THD corrente: n/a

THD tensão: n/a