

SLED9122SF LUMINARIA LINEAR DE SOBREPOR 2x2 14,4W/m 4000K 80 1M



Fluxo luminoso – 859 lm/m

Potência – 14,3 W/m

Intensidade pico – 304cd

CCT – 4082K




IRC – 82,0

Coordenada CIE 1931 – x- 0,378 y- 0,379

Data do ensaio

27/08/2024 11:22:15



Facho de abertura

111,5°


Rf 83,5



Fidelity index Rf

Rg 95,8


Gamut index Rg

Hue Bin	R _f	Shifts (%)	
		Chroma	Hue
1	80	-12%	-1%
2	83	-8%	6%
3	76	-4%	12%
4	86	1%	8%
5	89	2%	5%
6	94	3%	-2%
7	92	-3%	-4%
8	89	-6%	-2%
9	87	-8%	4%
10	77	-8%	11%
11	77	2%	15%
12	83	6%	7%
13	86	9%	-6%
14	86	5%	-7%
15	77	0%	-17%
16	77	-5%	-14%






TM-30: 83,5



CRI: 82,0 (R1-R8)



CRIRA R1-R8 / CRIR R1-R15

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
79,9	87,4	93,4	81,7	79,9	82,7	86,3	64,3	5,0	70,4	80,6	59,1	81,7	96,4	72,9

TM30 valores C. 16 valores extraídos dos 99.

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
79,7	82,7	76,4	86,5	89,2	93,6	91,7	89,3	87,2	77,4	76,8	83,3	85,9	85,7	77,4	77,1

Parametros de cor

Temperatura de cor	Índice de reprodução de cor	Reprodução de cor vermelho R9	Color fidelity	Color gamut	Color quality scale	Coordenada de cor cie 1931	Coordenada de cor cie 1931	Coordenada de cor	Coordenada de cor	Color deviation from black body
CCT	IRC	CRI R9	TM30 Rf	TM30 Rg	CQS	x	y	u	v	Δuv
4082 K	82,0	5,0	83,5	95,8	81,7	0,378	0,379	0,223	0,335	0,0018







Rf 83,5

Fidelity index Rf

Rg 95,8

Gamut index Rg

Hue Bin	R _f	Shifts (%)	
		Chroma	Hue
1	80	-12%	-1%
2	83	-8%	6%
3	76	-4%	12%
4	86	1%	8%
5	89	2%	5%
6	94	3%	-2%
7	92	-3%	-4%
8	89	-6%	-2%
9	87	-8%	4%
10	77	-8%	11%
11	77	2%	15%
12	83	6%	7%
13	86	9%	-6%
14	86	5%	-7%
15	77	0%	-17%
16	77	-5%	-14%



Avaliação todas as amostras de cores

Glare Evaluation According to UGR


p Ceiling		70	70	50	50	30	70	70	50	50	30
p Walls		50	30	50	30	30	50	30	50	30	30
p Floor		20	20	20	20	20	20	20	20	20	20
Room size X Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	21,7	22,9	21,9	23,2	23,4	21,7	22,9	21,9	23,2	23,4
	3H	23,1	24,4	23,5	24,7	24,9	23,1	24,4	23,5	24,7	24,9
	4H	23,7	24,9	24,1	25,2	25,5	23,7	24,9	24,1	25,2	25,5
	6H	24,2	25,3	24,5	25,5	25,9	24,2	25,3	24,5	25,5	25,9
	8H	24,3	25,3	24,7	25,7	26,1	24,3	25,3	24,7	25,7	26,1
	12H	24,4	25,3	24,7	25,7	26,1	24,4	25,3	24,7	25,7	26,1
4H	2H	22,3	23,5	22,7	23,7	24,0	22,3	23,5	22,7	23,7	24,0
	3H	24,0	25,0	24,4	25,4	25,8	24,0	25,0	24,4	25,4	25,8
	4H	24,7	25,6	25,1	26,0	26,6	24,7	25,6	25,1	26,0	26,6
	6H	25,2	26,1	25,7	26,4	26,8	25,2	26,1	25,7	26,4	26,8
	8H	25,4	26,2	25,9	26,5	26,9	25,4	26,2	25,9	26,5	26,9
	12H	25,4	26,1	26,0	26,5	27,0	25,4	26,1	26,0	26,5	27,0
8H	4H	25,0	25,7	25,5	26,1	26,5	25,0	25,7	25,5	26,1	26,5
	6H	25,6	26,2	26,1	26,7	27,3	25,6	26,2	26,1	26,7	27,3
	8H	25,9	26,4	26,4	26,9	27,6	25,9	26,4	26,4	26,9	27,6
	12H	26,0	26,5	26,6	27,0	27,6	26,0	26,5	26,6	27,0	27,6
12H	4H	25,0	25,6	25,5	26,1	26,5	25,0	25,6	25,5	26,1	26,5
	6H	25,7	26,2	26,2	26,8	27,4	25,7	26,2	26,2	26,8	27,4
	8H	26,0	26,4	26,6	26,9	27,5	26,0	26,4	26,6	26,9	27,5
Variation of the observer position for the luminaire distance S											
S = 1.0H		0,1 / -0,1					0,1 / -0,1				
S = 1.5H		0,1 / -0,3					0,1 / -0,3				
S = 2.0H		0,4 / -0,5					0,4 / -0,5				
Standard table		n/a					n/a				
Correction summand		n/a					n/a				
Corrected glare indices referring to 859 lm total luminous flux											


Coeficiente de utilização

Ceiling reflectance	80				70				50			30			10			0
Wall reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Floor reflectance	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	0
RCR	(RCR: Room Cavity Ratio) Room Values are expressed as percentage of Lumens delivered to the task surface																	
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	97	94	91	93	91	88	90	87	86	83
2	99	91	84	78	96	89	82	77	85	80	75	82	77	73	79	75	72	69
3	90	79	71	65	88	78	70	64	75	68	63	72	66	62	69	65	61	58
4	82	70	62	55	80	69	61	54	66	59	54	64	58	53	62	56	52	50
5	76	63	54	47	74	62	53	47	60	52	46	57	51	46	56	50	45	43
6	70	57	48	41	68	56	47	41	54	46	41	52	45	40	50	44	40	38
7	65	51	42	36	63	50	42	36	49	41	36	47	41	36	46	40	35	33
8	60	47	38	32	59	46	38	32	45	37	32	43	37	32	42	36	32	30
9	56	43	35	29	55	42	34	29	41	34	29	40	33	29	39	33	29	27
10	53	40	32	26	52	39	31	26	38	31	26	37	31	26	36	30	26	24

Quantidade de luminárias

Luminaire budgetary diagram





Beam intensities from 1-20m

1m	2m	3m	4m	5m	6m	7m	8m	9m	10m	11m	12m	13m	14m	15m	16m	17m	18m	19m	20m
3,3ft	6,6ft	9,8ft	13,1ft	16,4ft	19,7ft	23ft	26,2ft	29,5ft	32,8ft	36,1ft	39,4ft	42,7ft	45,9ft	49,2ft	52,5ft	55,8ft	59,1ft	62,3ft	65,6ft
304lx	76lx	34lx	19lx	12lx	8lx	6lx	5lx	4lx	3lx	3lx	2lx	2lx	2lx	1lx	1lx	1lx	1lx	1lx	1lx
28,2fcd	7,1fcd	3,1fcd	1,8fcd	1,1fcd	0,8fcd	0,6fcd	0,4fcd	0,3fcd	0,3fcd	0,2fcd	0,2fcd	0,2fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd

Intensities in 0° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
304	302	298	291	282	270	255	239	220	199	177	156	131	106	81	56	32	12	2	1
100%	100%	98%	96%	93%	89%	84%	79%	73%	65%	58%	51%	43%	35%	27%	18%	11%	4%	1%	0%

Intensities in 90° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
304	302	298	291	282	270	255	239	220	199	177	156	131	106	81	56	32	12	2	1
100%	100%	98%	96%	93%	89%	84%	79%	73%	65%	58%	51%	43%	35%	27%	18%	11%	4%	1%	0%

Intensities in 180° c-plane


0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
304	302	298	291	282	270	255	239	220	199	177	156	131	106	81	56	32	12	2	1
100%	100%	98%	96%	93%	89%	84%	79%	73%	65%	58%	51%	43%	35%	27%	18%	11%	4%	1%	0%

Intensities in 270° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
304	302	298	291	282	270	255	239	220	199	177	156	131	106	81	56	32	12	2	1
100%	100%	98%	96%	93%	89%	84%	79%	73%	65%	58%	51%	43%	35%	27%	18%	11%	4%	1%	0%

Beam angle 50%	Field angle 10%	Cutoff angle 2,5%	Intensity ratio in 120° cone	Intensity ratio in 90° cone
111,5°	160,9°	173°	78,8%	53,8%

iso-candela diagram




10%	30 cd
20%	61 cd
30%	91 cd
40%	122 cd
50%	152 cd
60%	182 cd
70%	213 cd
80%	243 cd
90%	273 cd

Conditions:

Number of c-planes: 16

Candela at center: 304 cd

iso-lux diagram



3%	91,1m lx
5%	0,152 lx
10%	0,304 lx
30%	0,911 lx
50%	1,52 lx

Conditions:

Number of c-planes: 16

Lux at center: 3,04 lx

Lux distribution on a surface when lamp is mounted at 10 meters from the surface.

Potência



Vttagem: 12,0 V

Corrente: 1,19 A

Frequência: 0 Hz

FP: 1,0

THD



THD corrente: n/a

THD tensão: n/a