


FITA SLED5203 IP65 9,6WM 4000K 80 - 1m



Fluxo luminoso – 1072 lm/m

Potência – 8,9 W/m

Intensidade pico – 329cd

CCT – 4504K




IRC – 83,6

Coordenada CIE 1931 – x- 0,360 y- 0,361

Data do ensaio

09/11/2022 09:02:31



Facho de abertura

122,2°


Rf 83,4



Fidelity index Rf

Rg 97,2

Gamut index Rg



Hue Bin	R _f	Shifts (%)	
		Chroma	Hue
1	79	-12%	-1%
2	85	-8%	6%
3	75	-4%	13%
4	85	1%	9%
5	88	3%	5%
6	93	4%	-1%
7	92	-2%	-4%
8	90	-5%	-2%
9	87	-8%	4%
10	77	-6%	13%
11	75	1%	16%
12	82	6%	9%
13	87	9%	-5%
14	87	5%	-5%
15	78	4%	-19%
16	79	-6%	-11%





TM-30: 83,4

CRI: 83,6 (R1-R8)



CRIRA R1-R8 / CRIre R1-R15

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
82,4	88,8	92,9	83,6	82,4	83,8	87,0	67,8	12,2	72,8	82,8	60,4	84,1	96,1	76,6

TM30 valores C. 16 valores extraídos dos 99.

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
78,6	84,7	75,4	85,2	88,3	92,6	92,3	90,3	86,9	76,7	75,3	81,8	86,6	86,6	77,6	79,3

Parametros de cor

Temperatura de cor	Índice de reprodução de cor	Reprodução de cor vermelho R9	Color fidelity	Color gamut	Color quality scale	Coordenada de cor cie 1931	Coordenada de cor cie 1931	Coordenada de cor	Coordenada de cor	Color deviation from black body
CCT	IRC	CRI R9	TM30 Rf	TM30 Rg	CQS	x	y	u	v	Δuv
4504 K	83,6	12,2	83,4	97,2	81,8	0,360	0,361	0,218	0,328	-0,0011







Rf 83,4

Fidelity index Rf

Rg 97,2

Gamut index Rg

Hue Bin	R _f	Shifts (%)	
		Chroma	Hue
1	79	-12%	-1%
2	85	-8%	6%
3	75	-4%	13%
4	85	1%	9%
5	88	3%	5%
6	93	4%	-1%
7	92	-2%	-4%
8	90	-5%	-2%
9	87	-8%	4%
10	77	-6%	13%
11	75	1%	16%
12	82	6%	9%
13	87	9%	-5%
14	87	5%	-5%
15	78	4%	-19%
16	79	-6%	-11%



Avaliação todas as amostras de cores

Glare Evaluation According to UGR


p Ceiling		70	70	50	50	30	70	70	50	50	30
p Walls		50	30	50	30	30	50	30	50	30	30
p Floor		20	20	20	20	20	20	20	20	20	20
Room size X Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	28,9	30,1	29,2	30,5	30,7	29,1	30,3	29,4	30,7	30,9
	3H	30,5	31,8	30,9	32,1	32,3	30,7	32,0	31,2	32,4	32,6
	4H	31,2	32,4	31,6	32,7	33,0	31,5	32,7	31,9	33,0	33,3
	6H	31,8	32,9	32,1	33,2	33,6	32,1	33,2	32,4	33,5	33,9
	8H	32,0	33,0	32,3	33,4	33,8	32,3	33,4	32,7	33,7	34,1
	12H	32,1	33,1	32,5	33,5	34,0	32,4	33,5	32,8	33,8	34,3
4H	2H	29,5	30,8	30,0	31,1	31,4	29,7	30,9	30,1	31,2	31,5
	3H	31,4	32,5	31,8	32,8	33,3	31,7	32,7	32,0	33,0	33,5
	4H	32,2	33,2	32,7	33,6	34,2	32,4	33,4	32,9	33,8	34,4
	6H	32,9	33,8	33,4	34,2	34,6	33,1	34,0	33,6	34,4	34,8
	8H	33,1	33,9	33,6	34,3	34,8	33,4	34,2	33,9	34,6	35,0
	12H	33,3	34,0	33,8	34,5	35,0	33,6	34,3	34,1	34,7	35,2
8H	4H	32,5	33,3	33,0	33,7	34,2	32,7	33,5	33,2	33,9	34,4
	6H	33,4	34,0	33,9	34,5	35,1	33,6	34,2	34,1	34,7	35,3
	8H	33,7	34,3	34,3	34,8	35,5	33,9	34,5	34,5	35,1	35,7
	12H	34,0	34,5	34,6	35,0	35,7	34,3	34,7	34,9	35,3	35,9
12H	4H	32,5	33,2	33,1	33,7	34,2	32,7	33,4	33,3	33,9	34,4
	6H	33,5	34,0	34,0	34,6	35,2	33,7	34,2	34,2	34,8	35,4
	8H	33,9	34,3	34,5	34,9	35,5	34,1	34,5	34,7	35,1	35,7
Variation of the observer position for the luminaire distance S											
S = 1.0H		0,1 / -0,1					0,1 / -0,1				
S = 1.5H		0,1 / -0,2					0,1 / -0,1				
S = 2.0H		0,3 / -0,4					0,3 / -0,4				
Standard table		n/a					n/a				
Correction summand		n/a					n/a				
Corrected glare indices referring to 1072 lm total luminous flux											


Coeficiente de utilização

Ceiling reflectance	80				70				50			30			10			0
Wall reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Floor reflectance	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	0
RCR	(RCR: Room Cavity Ratio) Room Values are expressed as percentage of Lumens delivered to the task surface																	
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101	99
1	107	102	98	93	105	100	96	92	95	92	89	91	88	86	87	85	83	81
2	97	88	81	75	94	86	80	74	83	77	72	79	74	70	76	72	68	66
3	88	77	69	62	86	75	67	61	72	65	60	69	63	59	66	61	57	55
4	81	68	59	52	78	67	58	51	64	56	50	61	55	50	59	53	49	46
5	74	61	51	44	72	59	51	44	57	49	43	55	48	43	53	47	42	40
6	68	54	45	38	66	53	45	38	51	44	38	49	43	37	48	42	37	35
7	63	49	40	34	61	48	40	34	47	39	33	45	38	33	43	37	33	30
8	59	45	36	30	57	44	36	30	42	35	30	41	34	29	40	34	29	27
9	55	41	33	27	53	40	32	27	39	32	27	38	31	26	37	31	26	24
10	51	38	30	24	50	37	29	24	36	29	24	35	28	24	34	28	24	22

Quantidade de luminárias

Luminaire budgetary diagram





Beam intensities from 1-20m

1m	2m	3m	4m	5m	6m	7m	8m	9m	10m	11m	12m	13m	14m	15m	16m	17m	18m	19m	20m
3,3ft	6,6ft	9,8ft	13,1ft	16,4ft	19,7ft	23ft	26,2ft	29,5ft	32,8ft	36,1ft	39,4ft	42,7ft	45,9ft	49,2ft	52,5ft	55,8ft	59,1ft	62,3ft	65,6ft
328lx	82lx	36lx	21lx	13lx	9lx	7lx	5lx	4lx	3lx	3lx	2lx	2lx	2lx	1lx	1lx	1lx	1lx	1lx	1lx
30,5fcd	7,6fcd	3,4fcd	1,9fcd	1,2fcd	0,8fcd	0,6fcd	0,5fcd	0,4fcd	0,3fcd	0,3fcd	0,2fcd	0,2fcd	0,2fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd

Intensities in 0° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
328	327	324	319	312	302	290	277	260	242	221	198	173	145	116	87	59	34	15	4
100%	100%	99%	97%	95%	92%	88%	84%	79%	74%	67%	60%	53%	44%	35%	26%	18%	10%	4%	1%

Intensities in 90° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
328	327	324	319	311	301	289	274	257	238	216	193	167	140	110	80	51	26	10	4
100%	100%	99%	97%	95%	92%	88%	84%	78%	72%	66%	59%	51%	43%	34%	24%	15%	8%	3%	1%

Intensities in 180° c-plane


0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
328	327	324	319	312	302	290	277	260	242	221	198	173	145	116	87	59	34	15	4
100%	100%	99%	97%	95%	92%	88%	84%	79%	74%	67%	60%	53%	44%	35%	26%	18%	10%	4%	1%

Intensities in 270° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
328	327	324	319	311	301	289	274	257	238	216	193	167	140	110	80	51	26	10	4
100%	100%	99%	97%	95%	92%	88%	84%	78%	72%	66%	59%	51%	43%	34%	24%	15%	8%	3%	1%

Beam angle 50%	Field angle 10%	Cutoff angle 2,5%	Intensity ratio in 120° cone	Intensity ratio in 90° cone
122,2°	169,1°	184,8°	74,0%	49,0%

iso-candela diagram




10%	33 cd
20%	66 cd
30%	99 cd
40%	131 cd
50%	164 cd
60%	197 cd
70%	230 cd
80%	263 cd
90%	296 cd

Conditions:

Number of c-planes: 16

Candela at center: 328 cd

iso-lux diagram



3%	98,5m lx
5%	0,164 lx
10%	0,328 lx
30%	0,985 lx
50%	1,64 lx

Conditions:

Number of c-planes: 16

Lux at center: 3,28 lx

Lux distribution on a surface when lamp is mounted at 10 meters from the surface.

Potência

Vttagem: 12,0 V

Corrente: 0,744 A

Frequência: 0 Hz

FP: 1,0

THD



THD corrente: n/a

THD tensão: n/a