

## SLED9079 - BARRA DE LED 23WM 3500K 90



As barras de LED, com potências de 18W e 23W, foram desenvolvidas para uma aplicação de alta performance. Possuem 120 ou 240 LEDs por metro, 8 temperaturas de cor e ainda a possibilidade de Tunable White. Na versão Tunable White, as temperaturas de cor vão de 1800K até 9000K e podem ser customizadas para intervalos de TCC específicos.

Fluxo luminoso – 1910 lm/m

Potência – 22,4 W/m


Intensidade pico – 664cd

CCT – 3400K



IRC – 94,7

Coordenada CIE 1931 – x- 0,408 y- 0,384



Facho de abertura

**110,2°**

Data do ensaio

21/07/2021 16:40:42


**Rf 90,7**



Fidelity index Rf

**Rg 98,7**


Gamut index Rg

Hue Bin	R <sub>f</sub>	Shifts (%)	
		Chroma	Hue
1	91	-4%	1%
2	93	-2%	2%
3	92	-1%	3%
4	93	-2%	0%
5	92	-5%	0%
6	96	0%	0%
7	92	-4%	2%
8	95	-2%	1%
9	90	-2%	7%
10	84	0%	11%
11	85	4%	9%
12	90	7%	1%
13	93	2%	-4%
14	89	4%	-7%
15	89	0%	-6%
16	88	-1%	-6%






TM-30: 90,7



CRI: 94,7 (R1-R8)



CRiRa R1-R8 / CRiRe R1-R15

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
96,2	98,8	98,0	93,6	94,9	95,4	92,9	87,8	74,2	95,6	93,7	76,8	97,6	98,8	94,4

TM30 valores C. 16 valores extraídos dos 99.

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
90,9	93,4	92,4	93,0	91,7	96,3	92,1	95,1	89,5	84,3	85,3	90,1	93,2	89,4	89,1	88,0

## Parametros de cor

Temperatura de cor	Índice de reprodução de cor	Reprodução de cor vermelho R9	Color fidelity	Color gamut	Color quality scale	Coordenada de cor cie 1931	Coordenada de cor cie 1931	Coordenada de cor	Coordenada de cor	Color deviation from black body
CCT	IRC	CRI R9	TM30 Rf	TM30 Rg	CQS	x	y	u	v	Δuv
3400 K	94,7	74,2	90,7	98,7	91,7	0,408	0,384	0,240	0,339	-0,0033







**Rf 90,7**

Fidelity index Rf

**Rg 98,7**

Gamut index Rg

Hue Bin	R <sub>i</sub>	Shifts (%)	
		Chroma	Hue
1	91	-4%	1%
2	93	-2%	2%
3	92	-1%	3%
4	93	-2%	0%
5	92	-5%	0%
6	96	0%	0%
7	92	-4%	2%
8	95	-2%	1%
9	90	-2%	7%
10	84	0%	11%
11	85	4%	9%
12	90	7%	1%
13	93	2%	-4%
14	89	4%	-7%
15	89	0%	-6%
16	88	-1%	-6%



Glare Evaluation According to UGR


p Ceiling		70	70	50	50	30	70	70	50	50	30
p Walls		50	30	50	30	30	50	30	50	30	30
p Floor		20	20	20	20	20	20	20	20	20	20
Room size X    Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	23,6	24,9	23,9	25,2	25,5	24,1	25,3	24,4	25,7	25,9
	3H	25,0	26,2	25,4	26,5	26,8	25,8	27,0	26,2	27,3	27,6
	4H	25,5	26,7	25,9	27,0	27,3	26,6	27,8	27,0	28,1	28,4
	6H	25,9	27,0	26,3	27,3	27,7	27,3	28,4	27,6	28,7	29,1
	8H	26,0	27,0	26,3	27,3	27,8	27,6	28,6	28,0	29,0	29,4
	12H	26,0	27,0	26,4	27,4	27,8	27,9	28,9	28,3	29,2	29,7
4H	2H	24,3	25,5	24,7	25,8	26,1	24,7	25,9	25,1	26,2	26,5
	3H	25,9	26,9	26,3	27,3	27,8	26,6	27,6	27,0	28,0	28,5
	4H	26,5	27,5	27,0	27,9	28,4	27,5	28,4	27,9	28,8	29,4
	6H	27,0	27,8	27,5	28,2	28,6	28,3	29,2	28,8	29,6	30,0
	8H	27,1	27,9	27,6	28,3	28,7	28,7	29,5	29,2	29,9	30,3
	12H	27,1	27,8	27,6	28,2	28,8	29,0	29,7	29,5	30,2	30,7
8H	4H	26,9	27,7	27,4	28,1	28,5	27,7	28,5	28,2	28,9	29,3
	6H	27,5	28,1	28,0	28,6	29,1	28,7	29,3	29,2	29,8	30,4
	8H	27,7	28,2	28,2	28,8	29,4	29,2	29,8	29,8	30,3	31,0
	12H	27,8	28,2	28,4	28,8	29,4	29,7	30,2	30,3	30,7	31,3
12H	4H	26,9	27,6	27,4	28,0	28,5	27,7	28,4	28,2	28,8	29,3
	6H	27,6	28,1	28,1	28,7	29,3	28,8	29,3	29,3	29,9	30,5
	8H	27,8	28,3	28,4	28,8	29,4	29,3	29,8	29,9	30,3	30,9
Variation of the observer position for the luminaire distance S											
S = 1.0H		0,1 / -0,1					0,1 / -0,1				
S = 1.5H		0,2 / -0,3					0,1 / -0,1				
S = 2.0H		0,4 / -0,6					0,3 / -0,4				
Standard table		n/a					n/a				
Correction summand		n/a					n/a				
Corrected glare indices referring to 1910 lm total luminous flux											


**Coeficiente de utilização**

Ceiling reflectance	80				70				50			30			10			0
Wall reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Floor reflectance	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	0
RCR	(RCR: Room Cavity Ratio) Room Values are expressed as percentage of Lumens delivered to the task surface																	
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101	98
1	108	103	98	94	105	100	96	93	96	93	90	92	89	86	88	86	84	81
2	98	89	82	77	95	87	81	76	84	78	74	80	76	72	77	73	70	67
3	89	78	70	63	87	77	69	63	74	67	61	71	65	60	68	63	59	57
4	82	69	61	54	79	68	60	53	65	58	52	63	56	51	60	55	51	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	45	54	49	44	42
6	69	56	47	40	67	55	46	40	53	45	40	51	44	39	49	43	39	37
7	64	51	42	36	62	50	41	35	48	41	35	46	40	35	45	39	34	32
8	60	46	38	32	58	45	37	32	44	37	31	43	36	31	41	35	31	29
9	56	42	34	29	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	39	31	26	37	30	26	36	30	25	35	29	25	23

**Quantidade de luminárias**

**Luminaire budgetary diagram**





### Beam intensities from 1-20m

1m	2m	3m	4m	5m	6m	7m	8m	9m	10m	11m	12m	13m	14m	15m	16m	17m	18m	19m	20m
3,3ft	6,6ft	9,8ft	13,1ft	16,4ft	19,7ft	23ft	26,2ft	29,5ft	32,8ft	36,1ft	39,4ft	42,7ft	45,9ft	49,2ft	52,5ft	55,8ft	59,1ft	62,3ft	65,6ft
664lx	166lx	74lx	41lx	27lx	18lx	14lx	10lx	8lx	7lx	5lx	5lx	4lx	3lx	3lx	3lx	2lx	2lx	2lx	2lx
61,7fcd	15,4fcd	6,9fcd	3,9fcd	2,5fcd	1,7fcd	1,3fcd	1fcd	0,8fcd	0,6fcd	0,5fcd	0,4fcd	0,4fcd	0,3fcd	0,3fcd	0,2fcd	0,2fcd	0,2fcd	0,2fcd	0,2fcd

### Intensities in 0° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
664	661	650	633	609	580	546	508	466	422	375	327	277	224	170	117	67	27	4	2
100%	100%	98%	95%	92%	87%	82%	76%	70%	64%	56%	49%	42%	34%	26%	18%	10%	4%	1%	0%

### Intensities in 90° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
664	660	650	633	610	582	549	512	471	429	383	338	291	243	195	147	103	65	36	19
100%	99%	98%	95%	92%	88%	83%	77%	71%	65%	58%	51%	44%	37%	29%	22%	16%	10%	5%	3%

### Intensities in 180° c-plane


0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
664	661	650	633	609	580	546	508	466	422	375	327	277	224	170	117	67	27	4	2
100%	100%	98%	95%	92%	87%	82%	76%	70%	64%	56%	49%	42%	34%	26%	18%	10%	4%	1%	0%

### Intensities in 270° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
664	660	650	633	610	582	549	512	471	429	383	338	291	243	195	147	103	65	36	19
100%	99%	98%	95%	92%	88%	83%	77%	71%	65%	58%	51%	44%	37%	29%	22%	16%	10%	5%	3%

Beam angle 50%	Field angle 10%	Cutoff angle 2,5%	Intensity ratio in 120° cone	Intensity ratio in 90° cone
110,2°	165,1°	183°	76,1%	52,0%

**iso-candela diagram**




10%	66 cd
20%	133 cd
30%	199 cd
40%	265 cd
50%	332 cd
60%	398 cd
70%	465 cd
80%	531 cd
90%	597 cd

Conditions:

Number of c-planes: 16

Candela at center: 664 cd

**iso-lux diagram**



3%	0,199 lx
5%	0,332 lx
10%	0,664 lx
30%	1,99 lx
50%	3,32 lx

Conditions:

Number of c-planes: 16

Lux at center: 6,64 lx

*Lux distribution on a surface when lamp is mounted at 10 meters from the surface.*

**Potência**


**Vttagem: 12,0 V**

**Corrente: 1,86 A**

**Frequência: 0 Hz**

**FP: 1,0**

**THD**



**THD corrente: n/a**

**THD tensão: n/a**