

FITA SLED8027 11WM 2700K 95 - 1m



Fluxo luminoso – 768 lm/m

Potência – 11,0 W/m

Intensidade pico – 243cd

CCT – 2717K




IRC – 97,1

Coordenada CIE 1931 – x- 0,464 y- 0,419

Data do ensaio

22/04/2020 16:30:42



Facho de abertura

119,9°


Rf 93,7



Fidelity index Rf

Rg 97,6


Gamut index Rg

Hue Bin	R _f	Shifts (%)	
		Chroma	Hue
1	94	-2%	1%
2	97	-1%	0%
3	96	-2%	-1%
4	92	-5%	-2%
5	94	-5%	1%
6	95	-2%	3%
7	93	-3%	3%
8	95	0%	3%
9	94	0%	4%
10	93	1%	5%
11	93	2%	4%
12	93	3%	-2%
13	93	0%	-5%
14	92	1%	-6%
15	93	-3%	0%
16	90	-1%	-7%






TM-30: 93,7



CRI: 97,1 (R1-R8)



CRIRA R1-R8 / CRIR R1-R15

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
98,4	98,3	96,8	98,7	97,7	99,1	96,6	91,6	79,4	94,9	98,0	87,1	98,5	97,1	94,3

TM30 valores C. 16 valores extraídos dos 99.

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
94,2	96,9	96,0	92,5	94,4	94,9	93,0	94,9	93,6	92,7	93,4	93,0	93,1	92,3	92,9	90,4

Parametros de cor

Temperatura de cor	Índice de reprodução de cor	Reprodução de cor vermelho R9	Color fidelity	Color gamut	Color quality scale	Coordenada de cor cie 1931	Coordenada de cor cie 1931	Coordenada de cor	Coordenada de cor	Color deviation from black body
CCT	IRC	CRI R9	TM30 Rf	TM30 Rg	CQS	x	y	u	v	Δuv
2717 K	97,1	79,4	93,7	97,6	92,5	0,464	0,419	0,261	0,354	0,0028







Rf 93,7

Fidelity index Rf

Rg 97,6

Gamut index Rg

Hue Bin	R _f	Shifts (%)	
		Chroma	Hue
1	94	-2%	1%
2	97	-1%	0%
3	96	-2%	-1%
4	92	-5%	-2%
5	94	-5%	1%
6	95	-2%	3%
7	93	-3%	3%
8	95	0%	3%
9	94	0%	4%
10	93	1%	5%
11	93	2%	4%
12	93	3%	-2%
13	93	0%	-5%
14	92	1%	-6%
15	93	-3%	0%
16	90	-1%	-7%



Glare Evaluation According to UGR


p Ceiling		70	70	50	50	30	70	70	50	50	30
p Walls		50	30	50	30	30	50	30	50	30	30
p Floor		20	20	20	20	20	20	20	20	20	20
Room size X Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	24,4	25,7	24,7	26,0	26,3	24,5	25,7	24,7	26,1	26,3
	3H	26,1	27,4	26,5	27,7	27,9	26,2	27,5	26,6	27,8	28,0
	4H	26,9	28,1	27,3	28,4	28,7	26,9	28,2	27,4	28,5	28,8
	6H	27,5	28,6	27,9	28,9	29,3	27,6	28,7	28,0	29,0	29,4
	8H	27,7	28,8	28,1	29,1	29,6	27,8	28,9	28,2	29,2	29,7
	12H	27,9	28,9	28,3	29,3	29,8	28,0	29,1	28,4	29,4	29,9
4H	2H	25,1	26,4	25,5	26,7	26,9	25,2	26,4	25,6	26,7	27,0
	3H	27,1	28,2	27,5	28,5	29,0	27,2	28,2	27,6	28,6	29,0
	4H	27,9	28,9	28,4	29,3	29,9	28,0	28,9	28,4	29,4	29,9
	6H	28,6	29,6	29,2	29,9	30,3	28,7	29,6	29,2	30,0	30,4
	8H	28,9	29,8	29,4	30,1	30,5	29,0	29,9	29,5	30,2	30,6
	12H	29,1	29,8	29,6	30,3	30,8	29,3	30,0	29,8	30,4	30,9
8H	4H	28,3	29,1	28,8	29,5	29,9	28,3	29,2	28,9	29,6	30,0
	6H	29,2	29,8	29,7	30,3	30,9	29,3	29,9	29,8	30,4	31,0
	8H	29,6	30,2	30,1	30,7	31,3	29,7	30,2	30,2	30,8	31,4
	12H	29,9	30,4	30,5	30,9	31,5	30,0	30,5	30,6	31,0	31,7
12H	4H	28,3	29,0	28,8	29,4	29,9	28,4	29,1	28,9	29,5	30,0
	6H	29,3	29,9	29,8	30,4	31,1	29,4	29,9	29,9	30,5	31,1
	8H	29,7	30,2	30,3	30,7	31,4	29,8	30,3	30,4	30,8	31,4
Variation of the observer position for the luminaire distance S											
S = 1.0H		0,1 / -0,1					0,1 / -0,1				
S = 1.5H		0,1 / -0,2					0,1 / -0,1				
S = 2.0H		0,3 / -0,3					0,3 / -0,3				
Standard table		n/a					n/a				
Correction summand		n/a					n/a				
Corrected glare indices referring to 768 lm total luminous flux											


Coeficiente de utilização

Ceiling reflectance	80				70				50			30			10			0
Wall reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Floor reflectance	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	0
RCR	(RCR: Room Cavity Ratio) Room Values are expressed as percentage of Lumens delivered to the task surface																	
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	101	101	101	99
1	108	103	98	94	105	100	96	92	96	92	89	92	89	86	88	86	84	81
2	98	89	82	76	95	87	80	75	83	77	73	80	75	71	76	73	69	67
3	89	78	69	62	86	76	68	62	73	66	60	70	64	59	67	62	58	56
4	81	68	59	52	78	67	58	52	64	57	51	62	55	50	60	54	49	47
5	74	61	52	45	72	60	51	44	57	50	44	55	49	43	53	47	43	41
6	68	55	46	39	66	54	45	39	52	44	38	50	43	38	48	42	37	35
7	63	50	41	34	62	49	40	34	47	39	34	45	39	33	44	38	33	31
8	59	45	36	30	57	44	36	30	43	35	30	42	35	30	40	34	30	28
9	55	41	33	27	54	41	33	27	39	32	27	38	32	27	37	31	27	25
10	52	38	30	25	50	38	30	25	36	29	24	35	29	24	34	28	24	22

Quantidade de luminárias

Luminaire budgetary diagram





Beam intensities from 1-20m

1m	2m	3m	4m	5m	6m	7m	8m	9m	10m	11m	12m	13m	14m	15m	16m	17m	18m	19m	20m
3,3ft	6,6ft	9,8ft	13,1ft	16,4ft	19,7ft	23ft	26,2ft	29,5ft	32,8ft	36,1ft	39,4ft	42,7ft	45,9ft	49,2ft	52,5ft	55,8ft	59,1ft	62,3ft	65,6ft
243lx	61lx	27lx	15lx	10lx	7lx	5lx	4lx	3lx	2lx	2lx	2lx	1lx	1lx	1lx	1lx	1lx	1lx	1lx	1lx
22,6fcd	5,7fcd	2,5fcd	1,4fcd	0,9fcd	0,6fcd	0,5fcd	0,4fcd	0,3fcd	0,2fcd	0,2fcd	0,2fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd	0,1fcd

Intensities in 0° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
243	243	240	235	229	221	211	200	187	172	156	140	122	102	81	60	39	20	7	2
100%	100%	99%	97%	94%	91%	87%	82%	77%	71%	64%	57%	50%	42%	33%	25%	16%	8%	3%	1%

Intensities in 90° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
243	243	240	235	229	221	211	200	187	172	156	140	122	102	81	60	39	20	7	2
100%	100%	99%	97%	94%	91%	87%	82%	77%	71%	64%	57%	50%	42%	33%	25%	16%	8%	3%	1%

Intensities in 180° c-plane


0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
243	243	240	235	229	221	211	200	187	172	156	140	122	102	81	60	39	20	7	2
100%	100%	99%	97%	94%	91%	87%	82%	77%	71%	64%	57%	50%	42%	33%	25%	16%	8%	3%	1%

Intensities in 270° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
243	243	240	235	229	221	211	200	187	172	156	140	122	102	81	60	39	20	7	2
100%	100%	99%	97%	94%	91%	87%	82%	77%	71%	64%	57%	50%	42%	33%	25%	16%	8%	3%	1%

Beam angle 50%	Field angle 10%	Cutoff angle 2,5%	Intensity ratio in 120° cone	Intensity ratio in 90° cone
119,9°	167,4°	181,5°	74,9%	49,9%

iso-candela diagram




10%	24 cd
20%	49 cd
30%	73 cd
40%	97 cd
50%	122 cd
60%	146 cd
70%	170 cd
80%	195 cd
90%	219 cd

Conditions:

Number of c-planes: 12

Candela at center: 243 cd

iso-lux diagram



3%	73,0m lx
5%	0,122 lx
10%	0,243 lx
30%	0,730 lx
50%	1,22 lx

Conditions:

Number of c-planes: 12

Lux at center: 2,43 lx

Lux distribution on a surface when lamp is mounted at 10 meters from the surface.

Potência

Vttagem: 12,0 V

Corrente: 0,920 A

Frequência: 0 Hz

FP: 1,0

THD



THD corrente: n/a

THD tensão: n/a